

Załącznik nr H2

Nazwa	SType	X	Y	Z	I or A	Li	R'w	Lw	Day histogram
		m	m	m	m, m _c	dB(A)	dB	dB(A)	
Inwerter 1	Punkt	651566,37	665053,37	1,00		0,0	0,0	84,0	pora dnia
Inwerter 2	Punkt	651533,68	665043,80	1,00		0,0	0,0	84,0	pora dnia
Inwerter 3	Punkt	651506,18	665035,73	1,00		0,0	0,0	84,0	pora dnia
Inwerter 4	Punkt	651499,92	665026,90	1,00		0,0	0,0	84,0	pora dnia
Inwerter 5	Punkt	651490,35	665018,69	1,00		0,0	0,0	84,0	pora dnia
Inwerter 6	Punkt	651483,22	665010,36	1,00		0,0	0,0	84,0	pora dnia
Inwerter 7	Punkt	651474,51	665002,17	1,00		0,0	0,0	84,0	pora dnia
Inwerter 8	Punkt	651465,99	664993,81	1,00		0,0	0,0	84,0	pora dnia
Inwerter 9	Punkt	651459,03	664985,31	1,00		0,0	0,0	84,0	pora dnia
Inwerter 10	Punkt	651452,25	664976,81	1,00		0,0	0,0	84,0	pora dnia
Inwerter 11	Punkt	651442,55	664958,33	1,00		0,0	0,0	84,0	pora dnia
Inwerter 12	Punkt	651437,32	664950,38	1,00		0,0	0,0	84,0	pora dnia
Inwerter 13	Punkt	651432,11	664941,75	1,00		0,0	0,0	84,0	pora dnia
Inwerter 14	Punkt	651425,14	664933,77	1,00		0,0	0,0	84,0	pora dnia
Inwerter 15	Punkt	651420,97	664925,32	1,00		0,0	0,0	84,0	pora dnia
Inwerter 16	Punkt	651416,62	664917,05	1,00		0,0	0,0	84,0	pora dnia
Inwerter 17	Punkt	651412,96	664908,79	1,00		0,0	0,0	84,0	pora dnia
Inwerter 18	Punkt	651408,26	664900,86	1,00		0,0	0,0	84,0	pora dnia
Inwerter 19	Punkt	651404,44	664891,91	1,00		0,0	0,0	84,0	pora dnia
Inwerter 20	Punkt	651400,96	664883,65	1,00		0,0	0,0	84,0	pora dnia
Inwerter 21	Punkt	651398,88	664875,08	1,00		0,0	0,0	84,0	pora dnia
Inwerter 22	Punkt	651394,87	664867,34	1,00		0,0	0,0	84,0	pora dnia
Inwerter 23	Punkt	651390,17	664859,06	1,00		0,0	0,0	84,0	pora dnia
Inwerter 24	Punkt	651436,44	664851,86	1,00		0,0	0,0	84,0	pora dnia
Inwerter 25	Punkt	651477,01	664894,58	1,00		0,0	0,0	84,0	pora dnia
Inwerter 26	Punkt	651478,33	664902,54	1,00		0,0	0,0	84,0	pora dnia
Inwerter 27	Punkt	651486,10	664910,39	1,00		0,0	0,0	84,0	pora dnia
Inwerter 28	Punkt	651491,14	664918,43	1,00		0,0	0,0	84,0	pora dnia
Inwerter 29	Punkt	651496,64	664927,72	1,00		0,0	0,0	84,0	pora dnia
Inwerter 30	Punkt	651503,43	664935,31	1,00		0,0	0,0	84,0	pora dnia
Inwerter 31	Punkt	651508,19	664944,33	1,00		0,0	0,0	84,0	pora dnia
Inwerter 32	Punkt	651515,71	664952,67	1,00		0,0	0,0	84,0	pora dnia
Inwerter 33	Punkt	651520,75	664960,47	1,00		0,0	0,0	84,0	pora dnia

Nazwa	SType	X	Y	Z	I or A	Li	R'w	Lw	Day histogram
		m	m	m	m,m _c	dB(A)	dB	dB(A)	
Inwerter 34	Punkt	651334,99	664974,14	1,00		0,0	0,0	84,0	pora dnia
Inwerter 35	Punkt	651338,29	664982,15	1,00		0,0	0,0	84,0	pora dnia
Inwerter 36	Punkt	651341,83	664990,41	1,00		0,0	0,0	84,0	pora dnia
Inwerter 37	Punkt	651346,87	664998,45	1,00		0,0	0,0	84,0	pora dnia
Inwerter 38	Punkt	651350,64	665007,95	1,00		0,0	0,0	84,0	pora dnia
Inwerter 39	Punkt	651363,12	665015,65	1,00		0,0	0,0	84,0	pora dnia
Inwerter 40	Punkt	651420,44	665025,29	1,00		0,0	0,0	84,0	pora dnia
Magazyn energii 1 Dach	Obszar	651551,50	664970,14	2,00	9,15	90,0	16,0	69,6	
Magazyn energii 1 Fasada 1	Obszar	651551,57	664967,28	2,00	3,22	90,0	16,0	68,1	
Magazyn energii 1 Fasada 2	Obszar	651552,30	664970,18	2,00	11,17	90,0	16,0	73,5	
Magazyn energii 1 Fasada 3	Obszar	651551,45	664973,01	2,00	3,20	90,0	16,0	68,0	
Magazyn energii 1 Fasada 4	Obszar	651550,71	664970,10	2,00	11,77	90,0	16,0	73,7	
Magazyn energii 2 Dach	Obszar	651549,41	664970,12	2,00	9,15	90,0	16,0	69,6	
Magazyn energii 2 Fasada 1	Obszar	651549,48	664967,26	2,00	3,22	90,0	16,0	68,1	
Magazyn energii 2 Fasada 2	Obszar	651550,22	664970,16	2,00	11,17	90,0	16,0	73,5	
Magazyn energii 2 Fasada 3	Obszar	651549,36	664972,99	2,00	3,20	90,0	16,0	68,0	
Magazyn energii 2 Fasada 4	Obszar	651548,62	664970,08	2,00	11,77	90,0	16,0	73,7	
Magazyn energii 3 Dach	Obszar	651551,48	664963,88	2,00	9,15	90,0	16,0	69,6	
Magazyn energii 3 Fasada 1	Obszar	651551,54	664961,01	2,00	3,22	90,0	16,0	68,1	
Magazyn energii 3 Fasada 2	Obszar	651552,28	664963,92	2,00	11,17	90,0	16,0	73,5	
Magazyn energii 3 Fasada 3	Obszar	651551,42	664966,74	2,00	3,20	90,0	16,0	68,0	
Magazyn energii 3 Fasada 4	Obszar	651550,69	664963,84	2,00	11,77	90,0	16,0	73,7	
Magazyn energii 4 Dach	Obszar	651549,62	664963,84	2,00	9,15	90,0	16,0	69,6	
Magazyn energii 4 Fasada 1	Obszar	651549,69	664960,97	2,00	3,22	90,0	16,0	68,1	
Magazyn energii 4 Fasada 2	Obszar	651550,42	664963,88	2,00	11,17	90,0	16,0	73,5	
Magazyn energii 4 Fasada 3	Obszar	651549,56	664966,70	2,00	3,20	90,0	16,0	68,0	
Magazyn energii 4 Fasada 4	Obszar	651548,83	664963,80	2,00	11,77	90,0	16,0	73,7	
Magazyn energii 5 Dach	Obszar	651551,75	664957,79	2,00	9,15	90,0	16,0	69,6	
Magazyn energii 5 Fasada 1	Obszar	651551,82	664954,92	2,00	3,22	90,0	16,0	68,1	
Magazyn energii 5 Fasada 2	Obszar	651552,56	664957,83	2,00	11,17	90,0	16,0	73,5	
Magazyn energii 5 Fasada 3	Obszar	651551,70	664960,65	2,00	3,20	90,0	16,0	68,0	
Magazyn energii 5 Fasada 4	Obszar	651550,96	664957,75	2,00	11,77	90,0	16,0	73,7	
Magazyn energii 6 Dach	Obszar	651549,90	664957,75	2,00	9,15	90,0	16,0	69,6	

Nazwa	SType	X m	Y m	Z m	l or A m,m _c	Li dB(A)	R'w dB	Lw dB(A)	Day histogram
Magazyn energii 6 Fasada 1	Obszar	651549,96	664954,88	2,00	3,22	90,0	16,0	68,1	
Magazyn energii 6 Fasada 2	Obszar	651550,70	664957,79	2,00	11,17	90,0	16,0	73,5	
Magazyn energii 6 Fasada 3	Obszar	651549,84	664960,62	2,00	3,20	90,0	16,0	68,0	
Magazyn energii 6 Fasada 4	Obszar	651549,11	664957,71	2,00	11,77	90,0	16,0	73,7	
Magazyn energii 7 Dach	Obszar	651487,89	664967,64	2,00	9,16	90,0	16,0	69,6	
Magazyn energii 7 Fasada 1	Obszar	651487,84	664968,44	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 7 Fasada 2	Obszar	651485,01	664967,55	2,00	3,12	90,0	16,0	67,9	
Magazyn energii 7 Fasada 3	Obszar	651487,87	664966,83	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 7 Fasada 4	Obszar	651490,70	664967,72	2,00	3,31	90,0	16,0	68,2	
Magazyn energii 8 Dach	Obszar	651487,89	664965,91	2,00	9,16	90,0	16,0	69,6	
Magazyn energii 8 Fasada 1	Obszar	651487,85	664966,72	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 8 Fasada 2	Obszar	651485,02	664965,83	2,00	3,12	90,0	16,0	67,9	
Magazyn energii 8 Fasada 3	Obszar	651487,88	664965,11	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 8 Fasada 4	Obszar	651490,71	664966,00	2,00	3,31	90,0	16,0	68,2	
Magazyn energii 9 Dach	Obszar	651481,63	664967,18	2,00	9,16	90,0	16,0	69,6	
Magazyn energii 9 Fasada 1	Obszar	651481,59	664967,99	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 9 Fasada 2	Obszar	651478,76	664967,10	2,00	3,12	90,0	16,0	67,9	
Magazyn energii 9 Fasada 3	Obszar	651481,62	664966,38	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 9 Fasada 4	Obszar	651484,45	664967,27	2,00	3,31	90,0	16,0	68,2	
Magazyn energii 10 Dach	Obszar	651481,79	664965,40	2,00	9,16	90,0	16,0	69,6	
Magazyn energii 10 Fasada 1	Obszar	651481,74	664966,21	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 10 Fasada 2	Obszar	651478,91	664965,32	2,00	3,12	90,0	16,0	67,9	
Magazyn energii 10 Fasada 3	Obszar	651481,78	664964,60	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 10 Fasada 4	Obszar	651484,61	664965,49	2,00	3,31	90,0	16,0	68,2	
Magazyn energii 11 Dach	Obszar	651475,23	664966,85	2,00	9,16	90,0	16,0	69,6	
Magazyn energii 11 Fasada 1	Obszar	651475,18	664967,65	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 11 Fasada 2	Obszar	651472,36	664966,76	2,00	3,12	90,0	16,0	67,9	
Magazyn energii 11 Fasada 3	Obszar	651475,22	664966,04	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 11 Fasada 4	Obszar	651478,05	664966,93	2,00	3,31	90,0	16,0	68,2	
Magazyn energii 12 Dach	Obszar	651475,60	664964,94	2,00	9,16	90,0	16,0	69,6	
Magazyn energii 12 Fasada 1	Obszar	651475,55	664965,75	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 12 Fasada 2	Obszar	651472,73	664964,86	2,00	3,12	90,0	16,0	67,9	
Magazyn energii 12 Fasada 3	Obszar	651475,59	664964,14	2,00	11,39	90,0	16,0	73,6	

Nazwa	SType	X m	Y m	Z m	l or A m,m _c	Li dB(A)	R'w dB	Lw dB(A)	Day histogram
Magazyn energii 12 Fasada 4	Obszar	651478,42	664965,02	2,00	3,31	90,0	16,0	68,2	
Magazyn energii 13 Dach	Obszar	651469,17	664966,52	2,00	9,16	90,0	16,0	69,6	
Magazyn energii 13 Fasada 1	Obszar	651469,13	664967,32	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 13 Fasada 2	Obszar	651466,30	664966,44	2,00	3,12	90,0	16,0	67,9	
Magazyn energii 13 Fasada 3	Obszar	651469,16	664965,72	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 13 Fasada 4	Obszar	651471,99	664966,60	2,00	3,31	90,0	16,0	68,2	
Magazyn energii 14 Dach	Obszar	651469,34	664964,55	2,00	9,16	90,0	16,0	69,6	
Magazyn energii 14 Fasada 1	Obszar	651469,30	664965,35	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 14 Fasada 2	Obszar	651466,47	664964,46	2,00	3,12	90,0	16,0	67,9	
Magazyn energii 14 Fasada 3	Obszar	651469,33	664963,74	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 14 Fasada 4	Obszar	651472,16	664964,63	2,00	3,31	90,0	16,0	68,2	
Magazyn energii 15 Dach	Obszar	651462,91	664966,12	2,00	9,16	90,0	16,0	69,6	
Magazyn energii 15 Fasada 1	Obszar	651462,87	664966,93	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 15 Fasada 2	Obszar	651460,04	664966,04	2,00	3,12	90,0	16,0	67,9	
Magazyn energii 15 Fasada 3	Obszar	651462,90	664965,32	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 15 Fasada 4	Obszar	651465,73	664966,21	2,00	3,31	90,0	16,0	68,2	
Magazyn energii 16 Dach	Obszar	651463,02	664964,15	2,00	9,16	90,0	16,0	69,6	
Magazyn energii 16 Fasada 1	Obszar	651462,98	664964,95	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 16 Fasada 2	Obszar	651460,15	664964,06	2,00	3,12	90,0	16,0	67,9	
Magazyn energii 16 Fasada 3	Obszar	651463,01	664963,34	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 16 Fasada 4	Obszar	651465,84	664964,23	2,00	3,31	90,0	16,0	68,2	
Magazyn energii 17 Dach	Obszar	651456,60	664965,53	2,00	9,16	90,0	16,0	72,6	
Magazyn energii 17 Fasada 1	Obszar	651456,55	664966,33	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 17 Fasada 2	Obszar	651453,72	664965,45	2,00	3,12	90,0	16,0	67,9	
Magazyn energii 17 Fasada 3	Obszar	651456,59	664964,72	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 17 Fasada 4	Obszar	651459,41	664965,61	2,00	3,31	90,0	16,0	68,2	
Magazyn energii 18 Dach	Obszar	651456,57	664963,68	2,00	9,16	90,0	16,0	69,6	
Magazyn energii 18 Fasada 1	Obszar	651456,52	664964,49	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 18 Fasada 2	Obszar	651453,69	664963,60	2,00	3,12	90,0	16,0	67,9	
Magazyn energii 18 Fasada 3	Obszar	651456,56	664962,88	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 18 Fasada 4	Obszar	651459,39	664963,77	2,00	3,31	90,0	16,0	68,2	
Magazyn energii 19 Dach	Obszar	651361,38	664968,26	2,00	9,16	90,0	16,0	69,6	
Magazyn energii 19 Fasada 1	Obszar	651361,34	664969,07	2,00	11,39	90,0	16,0	73,6	

Nazwa	SType	X m	Y m	Z m	l or A m,m _c	Li dB(A)	R'w dB	Lw dB(A)	Day histogram
Magazyn energii 19 Fasada 2	Obszar	651358,51	664968,18	2,00	3,12	90,0	16,0	67,9	
Magazyn energii 19 Fasada 3	Obszar	651361,37	664967,46	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 19 Fasada 4	Obszar	651364,20	664968,35	2,00	3,31	90,0	16,0	68,2	
Magazyn energii 20 Dach	Obszar	651361,29	664966,41	2,00	9,16	90,0	16,0	69,6	
Magazyn energii 20 Fasada 1	Obszar	651361,25	664967,22	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 20 Fasada 2	Obszar	651358,42	664966,33	2,00	3,12	90,0	16,0	67,9	
Magazyn energii 20 Fasada 3	Obszar	651361,28	664965,61	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 20 Fasada 4	Obszar	651364,11	664966,50	2,00	3,31	90,0	16,0	68,2	
Magazyn energii 21 Dach	Obszar	651355,06	664967,80	2,00	9,16	90,0	16,0	69,6	
Magazyn energii 21 Fasada 1	Obszar	651355,02	664968,60	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 21 Fasada 2	Obszar	651352,19	664967,72	2,00	3,12	90,0	16,0	67,9	
Magazyn energii 21 Fasada 3	Obszar	651355,05	664967,00	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 21 Fasada 4	Obszar	651357,88	664967,88	2,00	3,31	90,0	16,0	68,2	
Magazyn energii 22 Dach	Obszar	651355,17	664966,02	2,00	9,16	90,0	16,0	69,6	
Magazyn energii 22 Fasada 1	Obszar	651355,12	664966,82	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 22 Fasada 2	Obszar	651352,29	664965,94	2,00	3,12	90,0	16,0	67,9	
Magazyn energii 22 Fasada 3	Obszar	651355,16	664965,22	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 22 Fasada 4	Obszar	651357,99	664966,10	2,00	3,31	90,0	16,0	68,2	
Magazyn energii 23 Dach	Obszar	651349,13	664967,54	2,00	9,16	90,0	16,0	69,6	
Magazyn energii 23 Fasada 1	Obszar	651349,09	664968,35	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 23 Fasada 2	Obszar	651346,26	664967,46	2,00	3,12	90,0	16,0	67,9	
Magazyn energii 23 Fasada 3	Obszar	651349,12	664966,74	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 23 Fasada 4	Obszar	651351,95	664967,63	2,00	3,31	90,0	16,0	68,2	
Magazyn energii 24 Dach	Obszar	651349,17	664965,76	2,00	9,16	90,0	16,0	69,6	
Magazyn energii 24 Fasada 1	Obszar	651349,13	664966,57	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 24 Fasada 2	Obszar	651346,30	664965,68	2,00	3,12	90,0	16,0	67,9	
Magazyn energii 24 Fasada 3	Obszar	651349,16	664964,96	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 24 Fasada 4	Obszar	651351,99	664965,85	2,00	3,31	90,0	16,0	68,2	
Magazyn energii 25 Dach	Obszar	651343,01	664967,15	2,00	9,16	90,0	16,0	69,6	
Magazyn energii 25 Fasada 1	Obszar	651342,97	664967,95	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 25 Fasada 2	Obszar	651340,14	664967,07	2,00	3,12	90,0	16,0	67,9	
Magazyn energii 25 Fasada 3	Obszar	651343,00	664966,34	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 25 Fasada 4	Obszar	651345,83	664967,23	2,00	3,31	90,0	16,0	68,2	

Nazwa	SType	X m	Y m	Z m	l or A m,m _c	Li dB(A)	R'w dB	Lw dB(A)	Day histogram
Magazyn energii 26 Dach	Obszar	651342,92	664965,24	2,00	9,16	90,0	16,0	69,6	
Magazyn energii 26 Fasada 1	Obszar	651342,87	664966,04	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 26 Fasada 2	Obszar	651340,04	664965,15	2,00	3,12	90,0	16,0	67,9	
Magazyn energii 26 Fasada 3	Obszar	651342,91	664964,43	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 26 Fasada 4	Obszar	651345,74	664965,32	2,00	3,31	90,0	16,0	68,2	
Magazyn energii 27 Dach	Obszar	651336,82	664966,89	2,00	9,16	90,0	16,0	69,6	
Magazyn energii 27 Fasada 1	Obszar	651336,77	664967,69	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 27 Fasada 2	Obszar	651333,94	664966,80	2,00	3,12	90,0	16,0	67,9	
Magazyn energii 27 Fasada 3	Obszar	651336,81	664966,08	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 27 Fasada 4	Obszar	651339,64	664966,97	2,00	3,31	90,0	16,0	68,2	
Magazyn energii 28 Dach	Obszar	651336,66	664965,10	2,00	9,16	90,0	16,0	69,6	
Magazyn energii 28 Fasada 1	Obszar	651336,61	664965,91	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 28 Fasada 2	Obszar	651333,78	664965,02	2,00	3,12	90,0	16,0	67,9	
Magazyn energii 28 Fasada 3	Obszar	651336,65	664964,30	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 28 Fasada 4	Obszar	651339,48	664965,19	2,00	3,31	90,0	16,0	68,2	
Magazyn energii 29 Dach	Obszar	651330,50	664966,49	2,00	9,16	90,0	16,0	69,6	
Magazyn energii 29 Fasada 1	Obszar	651330,45	664967,29	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 29 Fasada 2	Obszar	651327,62	664966,40	2,00	3,12	90,0	16,0	67,9	
Magazyn energii 29 Fasada 3	Obszar	651330,49	664965,68	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 29 Fasada 4	Obszar	651333,31	664966,57	2,00	3,31	90,0	16,0	68,2	
Magazyn energii 30 Dach	Obszar	651330,52	664964,56	2,00	9,16	90,0	16,0	69,6	
Magazyn energii 30 Fasada 1	Obszar	651330,47	664965,37	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 30 Fasada 2	Obszar	651327,64	664964,48	2,00	3,12	90,0	16,0	67,9	
Magazyn energii 30 Fasada 3	Obszar	651330,51	664963,76	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 30 Fasada 4	Obszar	651333,34	664964,65	2,00	3,31	90,0	16,0	68,2	
Magazyn energii 31 Dach	Obszar	651324,11	664966,11	2,00	9,16	90,0	16,0	69,6	
Magazyn energii 31 Fasada 1	Obszar	651324,07	664966,92	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 31 Fasada 2	Obszar	651321,24	664966,03	2,00	3,12	90,0	16,0	67,9	
Magazyn energii 31 Fasada 3	Obszar	651324,10	664965,31	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 31 Fasada 4	Obszar	651326,93	664966,19	2,00	3,31	90,0	16,0	68,2	
Magazyn energii 32 Dach	Obszar	651324,27	664964,07	2,00	9,16	90,0	16,0	69,6	
Magazyn energii 32 Fasada 1	Obszar	651324,23	664964,87	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 32 Fasada 2	Obszar	651321,40	664963,99	2,00	3,12	90,0	16,0	67,9	

Nazwa	SType	X m	Y m	Z m	l or A m,m _c	Li dB(A)	R'w dB	Lw dB(A)	Day histogram
Magazyn energii 32 Fasada 3	Obszar	651324,26	664963,27	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 32 Fasada 4	Obszar	651327,09	664964,15	2,00	3,31	90,0	16,0	68,2	
Magazyn energii 33 Dach	Obszar	651306,66	664966,59	2,00	9,16	90,0	16,0	69,6	
Magazyn energii 33 Fasada 1	Obszar	651306,62	664967,39	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 33 Fasada 2	Obszar	651303,79	664966,50	2,00	3,12	90,0	16,0	67,9	
Magazyn energii 33 Fasada 3	Obszar	651306,65	664965,78	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 33 Fasada 4	Obszar	651309,48	664966,67	2,00	3,31	90,0	16,0	68,2	
Magazyn energii 34 Dach	Obszar	651306,94	664964,67	2,00	9,16	90,0	16,0	69,6	
Magazyn energii 34 Fasada 1	Obszar	651306,90	664965,47	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 34 Fasada 2	Obszar	651304,07	664964,58	2,00	3,12	90,0	16,0	67,9	
Magazyn energii 34 Fasada 3	Obszar	651306,93	664963,86	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 34 Fasada 4	Obszar	651309,76	664964,75	2,00	3,31	90,0	16,0	68,2	
Magazyn energii 35 Dach	Obszar	651367,35	664968,56	2,00	9,16	90,0	16,0	69,6	
Magazyn energii 35 Fasada 1	Obszar	651367,31	664969,36	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 35 Fasada 2	Obszar	651364,48	664968,48	2,00	3,12	90,0	16,0	67,9	
Magazyn energii 35 Fasada 3	Obszar	651367,34	664967,76	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 35 Fasada 4	Obszar	651370,17	664968,64	2,00	3,31	90,0	16,0	68,2	
Magazyn energii 36 Dach	Obszar	651367,32	664966,60	2,00	9,16	90,0	16,0	69,6	
Magazyn energii 36 Fasada 1	Obszar	651367,28	664967,41	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 36 Fasada 2	Obszar	651364,45	664966,52	2,00	3,12	90,0	16,0	67,9	
Magazyn energii 36 Fasada 3	Obszar	651367,31	664965,80	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 36 Fasada 4	Obszar	651370,14	664966,69	2,00	3,31	90,0	16,0	68,2	
Magazyn energii 37 Dach	Obszar	651373,57	664968,76	2,00	9,16	90,0	16,0	69,6	
Magazyn energii 37 Fasada 1	Obszar	651373,52	664969,57	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 37 Fasada 2	Obszar	651370,69	664968,68	2,00	3,12	90,0	16,0	67,9	
Magazyn energii 37 Fasada 3	Obszar	651373,56	664967,96	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 37 Fasada 4	Obszar	651376,39	664968,85	2,00	3,31	90,0	16,0	68,2	
Magazyn energii 38 Dach	Obszar	651373,68	664966,74	2,00	9,16	85,0	16,0	63,6	
Magazyn energii 38 Fasada 1	Obszar	651373,64	664967,54	2,00	11,39	85,0	16,0	67,6	
Magazyn energii 38 Fasada 2	Obszar	651370,81	664966,65	2,00	3,12	85,0	16,0	61,9	
Magazyn energii 38 Fasada 3	Obszar	651373,67	664965,93	2,00	11,39	85,0	16,0	67,6	
Magazyn energii 38 Fasada 4	Obszar	651376,50	664966,82	2,00	3,31	85,0	16,0	62,2	
Magazyn energii 39 Dach	Obszar	651379,85	664969,04	2,00	9,16	90,0	16,0	69,6	

Nazwa	SType	X m	Y m	Z m	l or A m,m _c	Li dB(A)	R'w dB	Lw dB(A)	Day histogram
Magazyn energii 39 Fasada 1	Obszar	651379,81	664969,84	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 39 Fasada 2	Obszar	651376,98	664968,95	2,00	3,12	90,0	16,0	67,9	
Magazyn energii 39 Fasada 3	Obszar	651379,84	664968,23	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 39 Fasada 4	Obszar	651382,67	664969,12	2,00	3,31	90,0	16,0	68,2	
Magazyn energii 40 Dach	Obszar	651379,96	664966,94	2,00	9,16	90,0	16,0	69,6	
Magazyn energii 40 Fasada 1	Obszar	651379,92	664967,74	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 40 Fasada 2	Obszar	651377,09	664966,86	2,00	3,12	90,0	16,0	67,9	
Magazyn energii 40 Fasada 3	Obszar	651379,95	664966,14	2,00	11,39	90,0	16,0	73,6	
Magazyn energii 40 Fasada 4	Obszar	651382,78	664967,02	2,00	3,31	90,0	16,0	68,2	
Trasformator 1	Punkt	651312,20	664968,45	1,00		0,0	0,0	77,0	
Trasformator 2	Punkt	651312,36	664966,84	1,00		0,0	0,0	77,0	
Trasformator 3	Punkt	651312,66	664965,51	1,00		0,0	0,0	77,0	
Trasformator 4	Punkt	651494,84	664967,22	1,00		0,0	0,0	77,0	
Trasformator 5	Punkt	651494,87	664966,01	1,00		0,0	0,0	77,0	
Trasformator 6	Punkt	651494,76	664964,93	1,00		0,0	0,0	77,0	
Trasformator 7	Punkt	651494,64	664963,86	1,00		0,0	0,0	77,0	
Trasformator 8	Punkt	651562,61	664970,79	1,00		0,0	0,0	77,0	
Trasformator 9	Punkt	651562,64	664969,45	1,00		0,0	0,0	77,0	
Trasformator 10	Punkt	651562,81	664967,85	1,00		0,0	0,0	77,0	